

Krootuse katlamaja tarbijate soojuskoormused

Hoone	Elanike/ töötajate arv	Kõetav ruumala m³	Arvutuslik kütte võimsus kW	Arv. sooja vee koormus kW	Kokku küte+soe vesi kW	Arv. soojuste vajadus aastas MWh	Erikulu 1997 kWh/m²a	Erikulu 1997 Kr/m²a	Arv. erikulu kWh/m²a
Kõlliste vald									
Elamu, 6	22	1360	33.5	14.9	48.4	139.2	57.4	82.6	102.3
Elamu, 16	30	4082	89.3	20.4	109.7	300.0	43.4	62.5	73.5
Elamu, 24	54	7113	155.6	36.6	192.3	527.0	25.7	38.6	74.1
Elamu, 24	69	6911	151.2	46.8	198.0	553.0	38.1	60.4	80.0
Elamu, 24	72	6444	141.0	48.9	189.8	534.6	32.0	51.1	83.0
Elamu, 16	28	3493	80.3	19.0	99.2	262.5	33.8	48.7	75.1
Koolimaja	176	14892	296.0	6.8	302.8	731.5	32.2	71.8	49.1
Lasteaed	50	1583	39.4	9.7	49.1	140.0	54.3	147.9	88.4
Kokku		45878	986.3	203.1	1189.4	3187.9	34.7	60.7	69.5